

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**

**Periodical Renewal Fire Certificate**

From:  
 District Disaster Response & Fire Officer  
 Andhra Pradesh, Palnadu

To:  
 To The District Educational Officer,,  
 Educational  
 Department, Narasaraopet, Palnadu Distret.

**File No: 19054/PLN/DFO/2023, Date: 19/07/2023**

**Occupancy NoC RC Number: 2963/A3/2013**

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **Durga Public School,, represented by Durga public School, Dachepalli (Village and Mandalam),** - Regarding.

- Ref: 1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.90 Home(Prison & Fire Services), Dt 13-08-2021 Á G.O.No 120 Home (Prisons & Fire), Dt 25-10-2021
2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
3. This Office NOC for Occupancy Rc No. 2963/A3/2013, Dt.28/08/2013
4. Renewal NOC For Occupancy 2963/A3/2013, Dt.28/10/2019
5. Online Application for Renewal NOC of Durga public School, Dachepalli (Village and Mandalam), - Inspection report called for Regarding.
6. Online Inspection Report submitted by Officers of this Department on 19-07-2023.

<< 0 >>

The Management of Durga Public School,, represented by Durga public School, Dachepalli (Village and Mandalam), has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.43713/- vide challan No. 71136833982023, Dated 19/06/2023 at Sbi, Online.

**Durga Public School**

- This certificate is being issued as per G.O.Ms.No:90,Home(Prisons & Fire),Dt:13-08-2021 & GO.No:120,Home(Prisons & Fire),Dt-25-10-2021
- The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
- The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Durga public School Dachepalli (Village and Mandalam),**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Periodical Renewal Fire Certificate is valid from 28/08/2020 to 27/08/2023.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. The Applicant/Management has agreed to comply with proposed revision of fire safety measures, which were sent to government vide Rc No. /MSB/Section/2023 Dt. 11-05-2023 or any other fire safety measures as may be approved by the government from time to time.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

The Management has to maintain Fire Safety Measures and other installations in good working condition at all times and the Responsibility of Fire Fighting equipment maintenance lies with the management as seen

This Renewal NOC is issued form Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.

This Renewal NOC is valid for Three year only and It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.140, Home (Prisons tested by the committee at the time of inspection & Fire Service) Department.Dt.04-09-2015. two months before expire of this No Objection Certificate.

Your Sincerely,

 19/7/23

District Disaster Response & Fire Officer Andhra Pradesh, Palnadu

Copy to Management Durga public School, Durga Public School,Dachepalli (Village and Mandalam),Palnadu District

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned